Corrosion Report




Equipment Equip. Loc				55-003-001 1100 OVHD					Retireme Last Insp Next Insp	ng Life (Yea nt Date ection Date ection Date Corrosion R		4.99 01/26/201 02/01/201 07/30/201 56.16	2
DP	MEAS	DP	DP	DT	BASE	MEAS	MEAS	MEAS	NEAR	LAST	MIN	CCR	REM
ID	METH	STAT	SZ	TYPE		5	4	3			VALUE		LIFE
001.U	UT	Α	36.00	ELL	0.660 02/07					0.560 02/12	0.140	20.06	20.94
002.U	UT	Α	36.00	TEE	0.670 02/07					0.670 02/12	0.140	0.00	∞
003.U	UT	Α	24.00	RED	0.530 02/07					0.520 02/12	0.140	2.01	189.43
004.U	UT	Α	24.00	ELL	0.640 02/07					0.590 02/12	0.140	10.03	44.87
005.U	UT	Α	24.00	TEE	0.590 02/07					0.500 02/12	0.140	18.05	19.94
006.U	UT	Α	18.00	ELL	0. 49 0 02/07					0.400 02/12	0.140	18.05	14.40
007.U	UT	Α	18.00	ELL	0.700 02/07					0.420 02/12	0.140	56.16	4.99
U.800	UT	Α	18.00	ELL	0.490 02/07					0.480 02/12	0.140	2.01	169.49
009.U	UT	Α	18.00	ELL	0.500 02/07					0.490 02/12	0.140	2.01	174.48
010.U	UT	Α	24.00	RED	0.520 02/07					0.520 02/12	0.140	0.00	∞
011.U	UT	Α	24.00	ELL	0.600 02/07					0.420 02/12	0.140	36.10	7.76
012.U	UT	Α	24.00	TEE	0.560 02/07					0.560 02/12	0.140	0.00	∞
013.U	UT	Α	18.00	ELL	0. 4 90 02/07					0.500 02/12	0.140	0.00	∞
014.U	UT	Α	18.00	ELL	0.600 02/07					0.400 02/12	0.140	40.12	6.48
015.U	UT	Α	18.00	ELL	0.540 02/07					0.500 02/12	0.140	8.02	44.87
016.U	UT	Α	18.00	ELL	0.560 02/07					0.520 02/12	0.140	8.02	47.36
022.U	UT	Α	8.00	PIPE	0.320 07/76					0.290 05/06	0.140	1.01	149.25
023.U	UT	Α	3.00	PIPE	0.300 07/76				0.280 11/04	0.290 05/06	0.100	0.34	567.16

Corrosion Report



Equipment Equip. Loc				55-003-00 1100 OVH	1-I ID (C-1100 T	O E-1101A	VB/C/D)		Retireme Last Insp Next Insp	g Life (Yea nt Date ection Date ection Date Corrosion F	,	14.86 01/11/202 05/09/201 03/04/201 13.46	1
DP	MEAS	DP	DP	DT	BASE	MEAS	MEAS	MEAS	NEAR	LAST	MIN	CCR	REM
ID	METH	STAT	SZ	TYPE		5	4	3			VALUE		LIFE
017.U	UT	Α	36.00	ELL	0.400 07/82			0.370 10/04	0.370 12/07	0.340 03/10	0.140	13.46	14.86
018.U	UT	Α	26.00	PIPE	0.625 07/76	0.581 11/02	0.580 02/04	0.580 10/04	0.550 03/09	0.540 01/11	0.140	5.54	72.18
019.U	UT	Α	26.00	PIPE	0.625 07/76	0.600 06/98	0.591 11/02	0.580 10/04	0.540 03/09	0.530 01/11	0.140	5.54	70.37
021.U	UT	Α	36.00	PIPE	0.380 02/07					0.530 05/10	0.140	0.00	<u></u>
024.U	UT	Α	36.00	ELL	0.310 12/99			0.380 10/04	0.390 12/07	0.370 03/10	0.140	8.97	25.63
025.U	UT	Α	36.00	PIPE	0.344 11/02		0.360 02/04	0.340 05/06	0.540 03/09	0.530 01/11	0.140	5.51	70.79
026.U	UT	Α	36.00	PIPE	0. 324 11/ 02		0.250 0 6/05	0.330 05/06	0.520 03/09	0.520 01/11	0.140	0.00	σ
027.U	UT	Α	36.00	TEE	0.334 08/02	0.320 12/03	0.320 02/04	0.280 03/09	0.280 03/09	0.270 05/11	0.140	7.30	17.81






Division: Address:		3985 TEAL CT BENICIA, CA. 94510		Job Puro	Date: Job Number: Purchase Order: Reference Number:		5-9-1 31560 N/A N/A	<u>1</u> 06-006		Page: 1 of 1		
Client: Address: Contact: Location:	JOHN B	ON FILE JOHN B. RICHMOND		Cod Proc Acc	Code/Specification: Procedure: Acceptance Criteria:		C-1100 ASME SEC V 100-UT-001 B31.3 ULTRASONIC					
Inspection (Aethod	☐ Immersion ☐ Longitud ☐ C-scan		☐ Contact			Thru-Transm) B-scan		⊠т	C hickness Me ther:	asure	
Model 36 DL PL		Serial No. 012317412		CalsiDue Date 1-18-12			Franchices Po Frequen 5 MHZ	y y	V 5 / j	S £5 & 1 € 3/8"	Sérial/No. 666110	
PRE S		PRE SE	A.C. 19 75. 15	Amplitude PRE SET	Contract of the last of the last		Cal. Standard Scan Equipm Couplant:		002 N/A			
Additional I	oformatio	n:					Couplant:		SONO	950		
Test Results Quantity Inspected: Quantity Accepted: Quantity Rejected: PERFORMED ULTRASONIC INSPECTION ON OVHD LINE 36" OFF OF C-1100. HAD TO CLOSE GRID AND OR SCAN TML'S 17, 24, & 27 ON DRAWING 0955-003-001.												
NO INDICA DATA SHE	TION'S F ET FOR R	OUND AT THE EADING'S.	HE TIM	IE OF INSPEC	TION, SEE	TA 3	TACHED DI	RAWIN	NG FOR	TML LOCA	ATION'S AND U	Т
Technician, Lo CLINT EME		5-9-11		Customer (sign	1):			Mar	agement	Review (sign):	\dashv
This tener is	not to be							<u>-</u>		100-FORM-0	08 Rev. 1.1 (03/12/20	<u></u>)09)




Northern California 2465 Vista Del Monte, Ste. F Concord, CA 94520 Phone: (925) 685-4991 Fax: (310) 793-7298


Custor	Customer							Report #					
Unit/E	quipmen	.4	CUS	<u> </u>			N/A						
Ombe	darbinen	ov	HD LINE	C-1100			Drawing#			System #			
		· · · · · · · · · · · · · · · · · · ·		CGUT AI	ND OR S	CAN ON 7	0955-003-001 O N THE Y AND TWO ELBOW'S			OVHE)		
TML	READING				T	T		1	LLDOW)		T	T
17	0.36	LOW							l			 	
24	0.37	LOW						1					
27	0.27	LOW											
<u> </u>	 	<u> </u>	<u> </u>		ļ								
·	 	 	-		<u> </u>	<u> </u>							
		 		-	-	-		 					
		 						 		ļ			
		 							ļ	ļ			
					 				ļ			ļ	
						 		 		 			<u> </u>
							·				 		
	ļ										-		
ļ		<u> </u>	ļ										
				ļ									
	 			ļ									
				1	 			<u> </u>					
				<u> </u>	-			<u> </u>	ļ				
			 		 			 					
					 		····			<u> </u>			
				<u> </u>				 	 		<u> </u>		
				1	İ	 				 	<u> </u>		ļ
										 			
								-	 	 			
				<u> </u>	ļ								
	 				ļ								
					<u> </u>								
				 				 	ļ				
				†	<u> </u>	-			<u> </u>	ļ			
						1		<u> </u>	 				
								 					
							····	 	***************************************	, , , , , , , , , , , , , , , , , , ,			
								1					
	ļ												
	-												
L	.		l	L	L		·····		L				
Techni	cian Nan	ne		CI	INT EME	LIA		_	Date		05/	09/11	
Signatu	Signature CLINT EMELIA Date 05/09/11												

2-27



EPA






LOOKING EAST INTO CITOO

Pacific Technical	Client: CUSA	Unit: D) R 40RUDE	Technician: C EMELIA
Services	Equipment: OVHD Live 36"	Comments: COUT - SCAN	Date: 5-9-11
			PTS-0003 REV. 03/07

TML 24 30° ELBOW



Pacific Technical	Client: CVSA	Unit: DiR 4 crupe	Technician: CEwelra
Services	Equipment: WHD LWE 36"	Comments: Court 's Scar	Date: 5-9-ti
			DTO 0000 DEM 0007



CHEVRON RICHMOND FACILITY AUT REPORT CRUDE OVERHEAD LINE APRIL 2011



AUT INSPECTION RICHMOND FACILITY APRIL 2011

Client: Location: Item:

Unit:

Richmond Facility Richmond, CA USA Crude Overhead line

4 Crude

Inspector: AUT Operators:

John Beauregard Mr. Adam Maltsberger

Inspection Overview:

On April 27th. of 2011 Chevron Richmond Facility requested that ETC perform Automated Ultrasonic Testing (AUT) on the Crude Overhead Line. The Unit Inspector Mr. John Beauregard selected random areas of the line to be examined. This inspection was performed to give an idea of the overall damage that could exist in the piping currently. Attached are drawings showing the locations of all scans along with a colored C-scan image detailing the thickness ranges of the piping wall.

Inspection Specifications:

A longitudinal wave automated ultrasonic instrument was used for the examinations. The instrument is capable of storing all A-scan waveforms while displaying both B & C-scans for review. The instrument was encoded to track all locations in the X and Y position. A focused 10MHz, ½" diameter immersion transducer was utilized to propagate ultrasound into the Piping. The transducer was incremented 0.100" (X-axis direction) x 0.100" (Y-axis direction) while acquiring all the data. All ultrasonic parameters are stored on the system for further review if required.

Inspection Results:

Please refer to Drawings / Pictures for Section Layouts

Section #1 Results:

After the AUT data was acquired and analyzed it is determined that corrosion exists in all areas scanned.. The low for all scans is a 0.302" found in scan F4. All low areas detected are determined to be actual corrosion and not laminar reflectors. *Note: There was no paint/coating on the pipe at time of inspection, but some rust/scale was noticed. Minimum thickness, average thickness and scan dimensions for each scan are noted below:

Note: Scan F1 had to be separated from the merged C-scan image, due to the dramatic thickness change caused by the Hastelloy liner.

Scan #	Minimum Thickness	Average Thickness	Scan Lengths	Scan Widths
F1	0.500"	0.548"	114.0"	20.0"
F2	0.328"	0.383"	114.0"	20.0"
F3	0.328"	0.380"	92.0"	20.0"
F4	0.302"	0.355"	70.5."	20.0"

Section #2 Results:

After the AUT data was acquired and analyzed it is determined that corrosion exists in the area scanned. The low for this scan is a 0.318". All low areas detected are determined to be actual corrosion and not laminar reflectors. *Note: There was no paint/coating on the pipe at time of inspection, but some rust/scale was noticed. Minimum thickness, average thickness and scan dimensions for each scan are noted below:

Scan #	Minimum Thickness	Average Thickness	Scan Lengths	Scan Widths
F1	0.318"	0.379"	114.0"	20.0"

Section #3 Results:

After the AUT data was acquired and analyzed it is determined that corrosion exists in all areas scanned. The low for all scans is a 0.297" found in scan F1. All low areas detected are determined to be actual corrosion and not laminar reflectors. *Note: There was no paint/coating on the pipe at time of inspection, but some rust/scale was noticed. Minimum thickness, average thickness and scan dimensions for each scan are noted below:

Scan #	Minimum Thickness	Average Thickness	Scan Lengths	Scan Widths
F1	0.297"	0.377"	114.0"	20.0"
F2	0.312"	0.379"	114.0"	20.0"
F3	0.329"	0.380"	114.0"	20.0"


^{*}All scan areas are marked on the piping and can be referenced via the supplied drawings*


Inspectors Signature: Adam Maltsberger 04-29-2011




CRUDE OVERHEAD LINE VERTICAL SECTION (SECTION #1)














CRUDE OVERHEAD LINE HORIZONTAL SECTION (SECTION #2 & #3)



-







Crude unit overhead line inspection 5/11/2011

(0955-003-001) http://ric841dwgs.ric841.chevrontexaco.net/dwgs/insp/0955-003-001.dwf

Inspection summary:

The Crude Overhead line has two sections that were replaced during the 2007 S/D due to internal corrosion at the inlet elbow to E-1101D. There are two areas protected with a corrosion resistant hastelloy weld overlay as noted on the drawing. These areas appear to be nominal thickness with no detectable active corrosion. The inspection was concentrated on the unprotected Carbon steel areas of the vertical and horizontal run of the overhead line. These areas are actively corroding please see corrosion rate and remaining life calculations below. Current Remaining Life using Refinery Replacement Thickness for the thinnest area is 78 years located on section 3. The elbows were inspected by hand using a 1" x 1' grid pattern. This is the first AUT scan of this area so we are using a long term corrosion rate. We will scan this area again prior to the 2016 S/D to determine the short term corrosion rate at a repeatable location.

.375" nominal thickness

.297" worst location found

.078" recorded loss from 1976 because this is the first AUT inspection of these locations .002" per year based on long term corrosion rate from 1/1976 - 5/2011.

A remaining life to 0.140" in thickness is calculated to be 78 years at the current corrosion rates.

Hand UT Scan was performed on the elbows due to geometry and inability of using the AUT machine. CML 27 at the Y connection near the top of C-1100 above the hastelloy overlay has an area that is corroding at 0.007" per year short term and a remaining life of 17 years. We re-inspect this area every 3 years because it is an injection point and we will monitor as needed. There is no recommendation for the Oct. 2011 event at this time.

Inspection Overview:

On April 27th, 2011 Chevron Richmond Facility requested that ETC perform Automated Ultrasonic Testing (AUT) on the Crude Overhead Line. The Unit Inspector Mr. John Beauregard selected random areas of the line to be examined. This inspection was performed to give an idea of the overall damage that could exist in the piping currently. Attached are drawings showing the locations of all scans along with a colored C-scan image detailing the thickness ranges of the piping wall.

Inspection Specifications:

A longitudinal wave automated ultrasonic instrument was used for the examinations. The instrument is capable of storing all A-scan waveforms while displaying both B & C-scans for review. The instrument was encoded to track all locations in the X and Y position. A focused 10MHz, ½" diameter immersion transducer was utilized to propagate ultrasound into the Piping. The transducer was incremented 0.100" (X-axis direction) x 0.100" (Y-axis direction) while acquiring all the data. All ultrasonic parameters are stored on the system for further review if required.

Inspection Results:

Please refer to Drawings / Pictures for Section Layouts




Section #1 Results:

After the AUT data was acquired and analyzed it is determined that corrosion exists in all areas scanned.. The low for all scans is a 0.302" found in scan F4. All low areas detected are determined to be actual corrosion and not laminar reflectors. *Note: There was no paint/coating on the pipe at time of inspection, but some rust/scale was noticed. Minimum thickness, average thickness and scan dimensions for each scan are noted below:

Note: Scan F1 had to be separated from the merged C-scan image, due to the dramatic thickness change caused by the Hastelloy liner.

Minimum Thickness	Average Thickness
0.500"	0.548"
0.328"	0.383"
0.328"	0.380"
0.302"	0.355"
	0.500° 0.328° 0.328°


Section #2 Results:



After the AUT data was acquired and analyzed it is determined that corrosion exists in the area scanned. The low for this scan is a 0.318". All low areas detected are determined to be actual corrosion and not laminar reflectors. *Note: There was no paint/coating on the pipe at time of inspection, but some rust/scale was noticed. Minimum thickness, average thickness and scan dimensions for each scan are noted below:

Scan # Minimum Thickness Average Thickness

Section #3 Results:



After the AUT data was acquired and analyzed it is determined that corrosion exists in all areas scanned. The low for all scans is a 0.297" found in scan F1. All low areas detected are determined to be actual corrosion and not laminar reflectors. *Note: There was no paint/coating on the pipe at time of inspection, but some rust/scale was noticed. Minimum thickness, average thickness and scan dimensions for each scan are noted below:

Scan #	Minimum Thickness	Average Thickness
F1	0.297"	0.377"
F2	0.312"	0.379"
F3	0.329"	0.380"

^{*}All scan areas are marked on the piping and can be referenced via the supplied drawings*